

Arizona Administrative Code, Title 18, Chapter 9

Table 1. Unit Design Flows

Wastewater Source	Applicable Unit	Sewage Design Flow per Applicable Unit, Gallons Per Day
Airport	Passenger (average daily number) Employee	4 15
Auto Wash	Facility	Per manufacturer, if consistent with this Chapter
Bar/Lounge	Seat	30
Barber Shop	Chair	35
Beauty Parlor	Chair	100
Bowling Alley (snack bar only)	Lane	75
Camp Day camp, no cooking facilities Campground, overnight, flush toilets Campground, overnight, flush toilets and shower Campground, luxury Camp, youth, summer, or seasonal	Camping unit Camping unit Camping unit Person Person	30 75 150 100-150 50
Church Without kitchen With kitchen	Person (maximum attendance) Person (maximum attendance)	5 7
Country Club	Resident Member Nonresident Member	100 10
Dance Hall	Patron	5
Dental Office	Chair	500
Dog Kennel	Animal, maximum occupancy	15

Dwelling For determining design flow for sewage treatment facilities under R18-9-B202(A)(9)(a) and sewage collection systems under R18-9-E301(D) and R18-9-B301(K), excluding peaking factor.	Person	80
Dwelling For on-site wastewater treatment facilities per R18-9-E302 through R18-9-E323: Apartment Building 1 bedroom 2 bedroom 3 bedroom 4 bedroom Seasonal or Summer Dwelling (with recorded seasonal occupancy restriction) Single Family Dwellings Other than Single Family Dwelling, the greater flow value based on: Bedroom count 1-2 bedrooms Each bedroom over 2 Fixture count	Apartment Apartment Apartment Apartment Resident see R18-9- A314(D)(1) Bedroom Bedroom Fixture unit	200 300 400 500 100 see R18-9- A314(D)(1) 300 150 25
Fire Station	Employee	45
Hospital All flows Kitchen waste only Laundry waste only	Bed Bed Bed	250 25 40
Hotel/motel Without kitchen With kitchen	Bed (2 person) Bed (2 person)	50 60
Industrial facility Without showers With showers Cafeteria, add	Employee Employee Employee	25 35 5
Institutions Resident Nursing home Rest home	Person Person Person	75 125 125
Laundry Self service Commercial	Wash cycle Washing machine	50 Per manufacturer, if consistent with this Chapter
Office Building	Employee	20

Park (temporary use)		
Picnic, with showers, flush toilets	Parking space	40
Picnic, with flush toilets only	Parking space	20
Recreational vehicle, no water or sewer connections	Vehicle space	75
Recreational vehicle, with water and sewer connections	Vehicle space	100
Mobile home/Trailer	Space	250
Restaurant/Cafeteria	Employee	20
With toilet, add	Customer	7
Kitchen waste, add	Meal	6
Garbage disposal, add	Meal	1
Cocktail lounge, add	Customer	2
Kitchen waste disposal service, add	Meal	2
Restroom, public	Toilet	200
School		
Staff and office	Person	20
Elementary, add	Student	15
Middle and High, add	Student	20
with gym & showers, add	Student	5
with cafeteria, add	Student	3
Boarding, total flow	Person	100
Service Station with toilets	First bay	1000
	Each additional bay	500
Shopping Center, no food or laundry	Square foot of retail space	0.1
Store	Employee	20
Public restroom, add	Square foot of retail space	0.1
Swimming Pool, Public	Person	10
Theater		
Indoor	Seat	5
Drive-in	Car space	10

Note: Unit flow rates published in standard texts, literature sources, or relevant area or regional studies are considered by the Department, if appropriate to the project.